



## FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1690

Certificate only valid if verified on website – [www.ifccertification.com](http://www.ifccertification.com)

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

**Incito Ltd.**

**22, KONSTANTINOU KANARI ARADIPPOU  
Larnaca, 7102  
Cyprus**

**Tel: 00357-70007759**

Who fabricate the following timber fire doors and or doorsets:

**Halspan EI30/EI30Sa, Halspan EI60/EI60Sa,  
Strebord EI30/EI30Sa, Strebord EI60/EI60Sa**

have satisfied the requirements of the SDP 01 Fire Resistant Timber Door scheme. This includes the testing of products to **EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed in the schedules referenced below.

Schedule refs: BMT/CAN/F13020, BMT/FEA/F13021, BMT/FEP/F14053, BMT/FEP/F14054

Initial Certification: 20 December 2021

Revised: 21 May 2024

Valid to: 19 December 2026

Issue No: 3

David Mowatt  
Head of IFC Certification /  
Kiwa Group Limited

*This certificate consists of 1 page.  
Publication of this certificate is permitted.*