



FIRE RESISTANT TIMBER GLAZED SCREENS

Certificate number: IFCC1552

This is a product certificate to certify that

Incito Ltd.

22, KONSTANTINOU KANARI ARADIPPOU
Larnaca, 7102
Cyprus

Tel: 00357-70007759

Who fabricate timber fire resisting elements with the following glasses:

**7mm Pyroguard EW30
11mm Pyroguard Maxi EW30 & EW60**

have satisfied the requirements of scheme SDP 09. This includes the testing of products to **BS476: Part 22, EN1363-1 or EN 1364-1** as appropriate, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications and fields of application to achieve from **30 mins to 60 mins integrity** are detailed in the schedule referenced below. As this certificate invokes CF257 it cannot remain valid after the expiry date of CF257.

Schedule ref: IFCC1552/S01



Initial certification: 29 January 2020
Reissued: 22 April 2022
Valid to: 28 January 2023
Issue status: 3



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.